



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



वसुधैव कुटुम्बकम्
ONE EARTH • ONE FAMILY • ONE FUTURE



Tel. No.: 033-24239651,24239658 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/103

Date: 20.04.2023

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 27.03.2023-02.04.2023.

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 07.04.2023.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)

SUPERINTENDING ENGINEER

Eastern Regional Power Committee, Kolkata

Reactive Energy (VARh) Charge Statement

for the period : 27-03-2023 to 02-04-2023

A. REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

Sr. No.	From	To	Amount Payable (Rs.)	Amount Receivable (Rs.)	Amount Receivable
					(Final After Adjustment)(Rs.)
1	BSPHCL	POOL	1488737	0	0
2	JUVNL	POOL	2716265	0	0
3	DVC	POOL	0	268544	268544
4	GRIDCO	POOL	0	100480	100480
5	SIKKIM	POOL	0	75133	75133
6	WBSETCL	POOL	1637296	0	0
-		Total	5842298	444157	444157

Note:
a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC.
b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

B. DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period : 27-03-2023 to 02-04-2023

Sr.No.	BENEFICIARY	Meter No	Line Name	MVA/H_HIGH	REACTIVE CHARGE_MVArh (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs.)
1	BSPHCL	ER-1154-A	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	1448	-235240	0	0	-235240
2		ER-1159-A	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	1507.6	-244816	0	0	-244816
3		ER-1175-A	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	1798.8	-290603	0	0	-290603
4		ER-1176-A	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	1794.5	-289908.5	0	0	-289908.5
5		ER-1226-A	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	-1631.1	264391	0	0	264391
6		ER-1228-A	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	-1602.1	259718	0	0	259718
7		ER-1231-A	HV side of 400/220 Patna ICT-3	294.6	-48465	0	0	-48465
8		ER-1243-A	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	-12.7	2095.5	0	0	2095.5
9		ER-1247-A	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	-13.7	2260.5	0	0	2260.5
10		ER-1274-A	HV side of 400/220 Darbhanga DMTCL ICT-1	0	0	0	0	0
11		ER-1275-A	HV side of 400/220 Darbhanga DMTCL ICT-2	0	0	0	0	0
12		ER-1296-A	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	1377.1	-223678	0	0	-223678
13		ER-1305-A	220 KV DUMRAON NEW(BSPHCL)-ARA(PG) LINE-1	740.1	-119639.5	0	0	-119639.5
14		ER-1309-A	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	32.3	-5329.5	0	0	-5329.5
15		ER-1310-A	220 KV NADHOKHAR(BSPHCL)-PUSAUJI(PG) LINE-1	-521.3	84296	0	0	84296
16		ER-1312-A	220 KV side of 220/132 Arահ ICT-1	-44.9	7334	0	0	7334
17		ER-1313-A	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	-41.8	6801	0	0	6801
18		ER-1347-A	400 KV SIDE BANKA 400/132 200 MVA ICT-2	0	0	0	0	0
19		ER-1348-A	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPHCL)-I	1881.8	-304149.5	0	0	-304149.5
20		ER-1349-A	400 KV SIDE BANKA 400/132 200 MVA ICT-1	0	0	0	0	0
21		ER-1355-A	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	33.6	-5544	0	0	-5544
22		ER-1358-A	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	31.7	-5230.5	0	0	-5230.5
23		ER-1362-A	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	0	0	0	0	0
24		ER-1376-A	220 KV NEW PURNEA(PG)-KHAGARIA(BSPHCL)	1437.2	-232799	0	0	-232799
25		ER-1386-A	HV side of 400/220 KV Biharsharif(PG) ICT-4	-275.9	45225.5	0	0	45225.5
26		ER-1395-A	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	0	0	0	0	0
27		ER-1407-A	HV side of 400/220 Patna ICT-2	310.1	-51036	0	0	-51036
28		ER-1411-A	400 KV SIDE GAYA 400/220 500 MVA ICT-1	0	0	0	0	0
29		ER-1419-A	400 KV SIDE GAYA 400/220 500 MVA ICT-2	0	0	0	0	0
30		ER-1436-A	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	36.8	-6072	0	0	-6072
31		ER-1442-A	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	0	0	0	0	0
32		ER-1788-A	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	1377.5	-223732.5	0	0	-223732.5
33		ER-1806-A	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	1281.8	-211175	0	0	-211175
34		ER-1816-A	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	0	0	0	0	0
35		ER-1819-A	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	-12	1980	0	0	1980
36		ER-1823-A	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	1170.5	-192996	0	0	-192996
37		ER-1829-A	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-1	-424.8	69782.5	0	0	69782.5
38		ER-1848-A	400 KV NAUBATPUR(BGCL)-PATNA(PG)-2	917.1	-151005	0	0	-151005
39		ER-1866-A	220 KV DUMRAON NEW(BSPHCL)-ARA (PG)-2	674.8	-109127.5	0	0	-109127.5
40		ER-1871-A	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-2	-433.1	71122.5	0	0	71122.5
41		ER-1873-A	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	11.3	-1864.5	0	0	-1864.5
42		ER-1875-A	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	0	0	0	0	0
43		ER-1879-A	400 KV NAUBATPUR(BGCL)-PATNA(PG)-1	922.9	-151966	0	0	-151966
44		ER-1882-A	220 KV side of 220/132 Arահ ICT-2	-48.4	7903.5	0	0	7903.5
45		ER-1922-A	HV side of 400/220 Patna ICT-1	418.6	-68861.5	0	0	-68861.5
46		ER-1933-A	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	0	0	0	0	0
47		ER-1934-A	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	0	0	0	0	0
48		ER-1941-A	400 KV JAKKANPUR(BGCL)-PATNA(PG)-1	-521.4	85842	0	0	85842
49		ER-1942-A	400 KV JAKKANPUR(BGCL)-PATNA(PG)-2	-377.4	62238.5	0	0	62238.5
50		ER-1945-A	220 KV MUZAFFARPUR(PG)-GORAUL(BSPHCL)-1	-311.1	49344	0	0	49344
51		ER-2206-A	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	-25.5	4207.5	0	0	4207.5
52		NP-6063-A	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	-828.2	136435	0	0	136435
53		NP-6068-A	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	-1330.3	218591	0	0	218591
54		NP-6069-A	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	-213.6	34979.5	0	0	34979.5
55		NP-6092-A	220 KV PUSAUJI(PG)-KARAMNASHA NEW(BSPHCL)	1446.9	-234131	0	0	-234131
56		NP-6093-A	220 KV PUSAUJI (PG) - DEHRI (BSPHCL)	-2822.7	454422	0	0	454422
57		NP-6094-A	132 KV PUSAUJI(PG)-MOHANIA(BSPHCL)	-7.7	1271.5	-223.3	-35764	-34492.5
58		NP-6095-A	132 KV PUSAUJI(PG)-KUDRA(BSPHCL)	21.5	-3543.5	117.8	18848	15304.5
59		NP-8665-A	220 KV NADHOKHAR(BSPHCL)-PUSAUJI (PG)-2	-425.9	68851	0	0	68851
-			Total	-	-1471821	-	-16916	-1488737

Sr.No	BENEFICIARY	Meter No	Line Name	MVAh_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAh_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs.)
1	DVC	ER-1147-A	220 KV MAITHON (PG) - DHANBAD (DVC) -II	-0.2	32	0	0	32
2		ER-1653-A	400 KV RTPS(DVC)-RANCHI(PG)	0	0	0	0	0
3		ER-1656-A	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	0	0	0	0	0
4		ER-1657-A	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	-19.6	3136	0	0	3136
5		ER-1658-A	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	0	0	0	0	0
6		ER-1668-A	220 KV MAITHON (PG) - DHANBAD (DVC) -I	0	0	0	0	0
7		ER-1711-A	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	0	0	0	0	0
8		ER-1717-A	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	-27.4	4431	0	0	4431
9		ER-1796-A	221 KV RANCHI(PG)-MTPS(DVC)	637.4	-103159	0	0	-103159
10		ER-1798-A	220 KV RANCHI(PG)-RAMGARH(DVC)	-2848.2	460274.5	0	0	460274.5
11		ER-1808-A	400 KV TATA JAMSHEDPUR (DVC) - BARIKUDA(PG)	-464	74662	0	0	74662
12		ER-2042-A	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	-18.9	3136.5	0	0	3136.5
13		ER-2044-A	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	-245.1	39216	0	0	39216
14		ER-2046-A	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	-229.8	36768	0	0	36768
15		ER-2086-A	400 KV MEJIA(DVC)-MAITHON(PG)	40.7	-6512	0	0	-6512
16		ER-2087-A	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	658.5	-106047.5	0	0	-106047.5
17		ER-2128-A	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	-107.7	17657.5	0	0	17657.5
18		ER-2129-A	400 KV KODERMA(DVC) - Gaya(PG)-I	-234.9	38115	0	0	38115
19		ER-2130-A	400 KV KODERMA(DVC) - Gaya(PG)-II	0	0	0	0	0
20		ER-2682-A	400 KV RTPS(DVC)-MAITHON(PG)	441.5	-70640	0	0	-70640
21		NP-6456-A	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	0	0	0	0	0
22		NP-6458-A	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	0	0	0	0	0
23		NP-7853-A	400 KV RANCHI(PG)-RTPS(DVC)-III	442.8	-71291.5	0	0	-71291.5
24		NP-7871-A	400 KV RANCHI(PG)-RTPS(DVC)-II	318.4	-51234.5	0	0	-51234.5
25		ER-2612-A	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	0	0	0	0	0
26		ER-2614-A	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	0	0	0	0	0
-		-	Total	-	268544	-	0	268544

Sr.No	BENEFICIARY	Meter No	Line Name	MVAh_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAh_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs.)
1	GRIDCO	ER-1054-A	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	0	0	0	0	0
2		ER-1055-A	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	0	0	0	0	0
3		ER-1058-A	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	-8.7	1435.5	0	0	1435.5
4		ER-1059-A	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	-5.1	841.5	0	0	841.5
5		ER-1117-A	400 KV SUNDERGARH(PG)-DPGC-1	-229	37730.5	0	0	37730.5
6		ER-1119-A	400 KV SUNDERGARH(PG)-DPGC-2	-231.3	38113.5	0	0	38113.5
7		ER-1553-A	HV side meter of 400/220 Baripada ICT-1	0	0	0	0	0
8		ER-1563-A	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	0	0	0	0	0
9		ER-1565-A	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	0	0	0	0	0
10		ER-1571-A	HV side meter of 400/220 Jeypore ICT-2	22.6	-3727	0	0	-3727
11		ER-1575-A	HV side meter of 400/220 Bolangir-ICT-1	-0.9	148.5	0	0	148.5
12		ER-1582-A	HV side meter of 400/220 Bolangir-ICT-2	0	0	0	0	0
13		ER-1583-A	HV side of 400/220 Pandiabili ICT-1	0	0	0	0	0
14		ER-1587-A	HV side meter of 400/220 KV Keonjhar ICT-2	0	0	0	0	0
15		ER-1589-A	HV side meter of 400/220 KV Keonjhar ICT-1	0	0	0	0	0
16		ER-1595-A	HV side meter of 400/220 Rengali ICT-2	0	0	0	0	0
17		ER-1598-A	HV side meter of 400/220 Rengali ICT-1	0	0	0	0	0
18		ER-1746-A	HV side meter of 400/220 Baripada ICT-2	0	0	0	0	0
19		ER-1747-A	HV side meter of 400/220 Baripada ICT-3	0	0	0	0	0
20		ER-1758-A	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	0	0	0	0	0
21		ER-1759-A	400 KV INDRAVATI (PG) - INDRAVATI P/H	0.4	-64	0	0	-64
22		ER-1776-A	HV side of 400/220 Pandiabili ICT-2	0	0	0	0	0
23		ER-1897-A	400 KV DUBRI(GRIDCO)-PANDIABILI(PG)	-25.4	4082	0	0	4082
24		ER-1900-A	400 KV DUBRI(GRIDCO)- BARIKUDA(PG)	-170.2	27626.5	0	0	27626.5
25		ER-2062-A	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	34.6	-5707	0	0	-5707
26		ER-2071-A	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-II	0.4	-64	0.4	64	0
27		ER-2072-A	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-I	0	0	0	0	0
28		NP-7991-A	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	0	0	0	0	0
			Total	-	100416	-	64	100480

Sr.No	BENEFICIARY	Meter No	Line Name	MVAh_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAh_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs.)
1	JUVNL	ER-1197-A	HV side meter of 400/220 Daltonganj ICT-1	267	-44054	0	0	-44054
2		ER-1221-A	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	21.1	-3459.5	0	0	-3459.5
3		ER-1230-A	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	13.8	-2262.5	0	0	-2262.5
4		ER-1252-A	221 KV RANCHI(PG)-HATIA(JUVNL)-II	4344.9	-700989	0	0	-700989
5		ER-1297-A	HV side meter of 400/220 Jamshedpur ICT- 3	-314.8	50735.5	0	0	50735.5
6		ER-1317-A	HV side meter of 400/220 Daltonganj ICT- 2	257.9	-42553.5	0	0	-42553.5
7		ER-1928-A	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	0	0	0	0	0
8		ER-2142-A	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	0	0	0	0	0
9		NP-5211-A	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	0	0	0	0	0
10		NP-5874-A	223 KV RANCHI(PG)-CHANDIL(JUVNL)	1653.2	-267652.5	0	0	-267652.5
11		NP-5879-A	220 KV RANCHI(PG)-HATIA(JUVNL)-I	4785.1	-772289.5	0	0	-772289.5
12		NP-6105-A	HV side meter of 400/220 Jamshedpur ICT-2	-328.8	52939	0	0	52939
13		NP-6106-A	HV side meter of 400/220 Jamshedpur ICT-1	-506	81638	0	0	81638
14		NP-7880-A	222 KV RANCHI(PG)-HATIA(JUVNL)-III	3846.8	-621329.5	0	0	-621329.5
15		NP-8727-A	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	666	-108785	0	0	-108785
16		NP-8739-A	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	2071	-338202	0	0	-338202
			Total	-	-2716264.5	-	0	-2716264.5

Sr.No	BENEFICIARY	Meter No	Line Name	MVAh_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAh_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs.)
1	SIKKIM	ER-1489-A	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	-90.3	14624	0	0	14624
2		ER-1490-A	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	-88.8	14382.5	0	0	14382.5
3		NP-8770-A	132 KV MELLI (SIKKIM) - RANGPO (PG)	-179.2	28894	0	0	28894
4		NP-8771-A	132 KV MELLI (SIKKIM) - SILIGURI (PG)	-106.4	17332	0	0	17332
			Total	-	75132.5	-	0	75132.5

Sr.No	BENEFICIARY	Meter No	Line Name	MVAh_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAh_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs.)
1	WBSETCL	ER-1040-A	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	1828.3	-297322.5	0	0	-297322.5
2		ER-1043-A	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	10.2	-1683	0	0	-1683
3		ER-1044-A	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	239.3	-39106	0	0	-39106
4		ER-1047-A	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	117	-19238.5	0	0	-19238.5
5		ER-1071-A	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	-986.4	159688.5	0	0	159688.5
6		ER-1072-A	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	-62.7	10349.5	0	0	10349.5
7		ER-1080-A	132 KV SILIGURI (PG) - NJP(WBSETCL)	-554.6	90158.5	0	0	90158.5
8		ER-1130-A	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	0	0	0	0	0
9		ER-1131-A	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	-8.7	1435.5	0	0	1435.5
10		ER-1133-A	400 KV GOKARNA(WB)-RAJARHAT(PG)	-252	41580	0	0	41580
11		ER-1138-A	400 KV GOKARNA(WB)-PURNEA(PG)	-103.6	17094	0	0	17094
12		ER-1141-A	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	187.3	-30275.5	0	0	-30275.5
13		ER-1466-A	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	0	0	0	0	0
14		ER-1471-A	400 KV JEERAT (WBSETCL) - RAJARHAT(PG)	0	0	-117.8	-18848	-18848
15		ER-1477-A	400 KV JEERAT(PG) - SUBHASGRAM (PG)	-56.7	9355.5	0	0	9355.5
16		ER-1482-A	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	-1293.4	210220	0	0	210220
17		ER-1483-A	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	321.3	-52353.5	0	0	-52353.5
18		ER-1484-A	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	496.1	-80845.5	0	0	-80845.5
19		ER-1485-A	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	-69.1	11397.5	0	0	11397.5
20		ER-1486-A	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	309.2	-50358	0	0	-50358
21		ER-1512-A	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	-1008	164308	0	0	164308
22		ER-1526-A	HV side of 400/220 KV RAJARHAT(PG) ICT-1	74.6	-12278	0	0	-12278
23		ER-1534-A	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	447.5	-72741	0	0	-72741
24		ER-1537-A	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	324.8	-52864.5	0	0	-52864.5
25		ER-1637-A	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-II	-42.9	7200.5	0	0	7200.5
26		ER-1639-A	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	-670.2	109436	0	0	109436
27		ER-1650-A	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	70.9	-11686	0	0	-11686
28		ER-1675-A	132 KV SILIGURI (PG) - NBU (WBSETCL)	-341.2	55651.5	0	0	55651.5
29		ER-1679-A	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	-17.5	2885.5	0	0	2885.5
30		ER-1683-A	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	0	0	0	0	0
31		ER-1685-A	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	0	0	0	0	0
32		ER-1693-A	220 KV GAZOLE(WB)-MALDA(PG)-1	280.2	-46203	0	0	-46203
33		ER-1696-A	220 KV GAZOLE(WB)-MALDA(PG)-2	2.8	-448	0	0	-448
34		ER-1739-A	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	3149.4	-510409.5	0	0	-510409.5
35		ER-1981-A	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-I(MAIN)	56	-9240	0	0	-9240
36		ER-1986-A	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	93.4	-15107	0	0	-15107
37		ER-2012-A	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	34.2	-5643	0	0	-5643
38		ER-2015-A	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	-37.1	6074	0	0	6074
39		ER-2016-A	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	-32	5254.5	0	0	5254.5
40		ER-2017-A	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	64.7	-10675.5	0	0	-10675.5
41		ER-2039-A	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	3883.6	-629645	0	0	-629645
42		ER-2045-A	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	895.1	-146167.5	0	0	-146167.5
43		ER-2096-A	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	71.1	-11391.5	0	0	-11391.5
44		ER-2101-A	400 KV JEERAT(WB)-NEW JEERAT(PM/JL) CKT-1	60	-9900	0	0	-9900
45		ER-2103-A	401 KV JEERAT(WB)-NEW JEERAT(PM/JL) CKT-2	62.2	-10263	0	0	-10263
46		ER-2109-A	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	1317.9	-215446	0	0	-215446
47		ER-2111-A	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	590.1	-96394	0	0	-96394
48		ER-2122-A	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	-164	26401.5	0	0	26401.5
49		ER-2125-A	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	685.8	-111497	0	0	-111497
50		NP-6548-A	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-I	-13.1	2243.5	0	0	2243.5
			Total	-	-1618448	-	-18848	-1637296

Note :

- 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARH,w.e.f. 31/03/2023 & 16.5 paise/KVARH, w.e.f. 01.04.2023.
- 2) For reactive energy, (+) means injection and (-) means drawal with respect to utility
- 3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.
- 4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTS.
- 5) "NA" means meter reading not available.
- 6) As per the decision taken in 147th OCC meeting ,the methodology for computation of Reactive Charges has been changed in conformity with other RPCs