



सत्यमेव जयते

भारत सरकार

Government Of India

विद्युत मंत्रालय

Ministry Of Power

पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14 Golf Club Road, Tollygunje-70033 Website: www.erpc.gov.in

NO. ERPC/EE/OPERATION/2023/1019

DATE: 27.10.2023

To

As per list enclosed.

Sub: Corrigendum to the Minutes of 208th OCC Meeting held on 17.10.2023 (Tuesday) physically at ERPC secretariat, Kolkata - reg.

17.10.2023 (मंगलवार) को ईआरपीसी सचिवालय, कोलकाता में भौतिक रूप से आयोजित 208वीं ओसीसी बैठक के कार्यवृत्त का शुद्धिपत्र - संबंध में।

Sir/Madam,

The 208th OCC meeting was held on 17.10.2023(Tuesday) physically at ERPC secretariat,Kolkata. The minutes of the said meeting was issued on 27.10.2023.. However based on the observations received, **Corrigendum to the minutes of 208th OCC meeting** is hereby issued .The same is attached at **Annexure-I** and also available at ERPC website (www.erpc.gov.in).

208वीं ओसीसी बैठक 17.10.2023 (मंगलवार) को ईआरपीसी सचिवालय, कोलकाता में आयोजित की गई। उक्त बैठक का कार्यवृत्त 27.10.2023 को जारी किया गया था। हालांकि, प्राप्त टिप्पणियों के आधार पर, 208वीं ओसीसी बैठक के कार्यवृत्त का शुद्धिपत्र जारी किया जाता है। यह अनुलग्नक-1 में संलग्न है और ईआरपीसी वेबसाइट पर भी उपलब्ध है। (www.erpc.gov.in).

This corrigendum shall form part and parcel of the earlier issued minutes of 208th OCC meeting. यह शुद्धिपत्र 208वीं ओसीसी बैठक के पहले जारी किए गए कार्यवृत्त का हिस्सा होगा।

Regards/ सम्मान,

Yours faithfully/ आपका विश्वासी,

अलीक
27.10.23

A.De

DD(Operation)

डीडी(ऑपरेशन)

LIST OF ADDRESSES:

1. CHIEF ENGINEER (TRANS., O&M), BSPTCL, PATNA, (FAX NO. 0612-2504557/2504937)
2. CHIEF ENGINEER (System Operation), BSPTCL, PATNA, (FAX NO. 0612-2504557/2504937)
3. CHIEF ENGINEER, TRANSMISSION (O&M), JUSNL, RANCHI (FAX NO.-0651-2490486/2490863)
4. CHIEF ENGINEER, TVNL, DORANDA, RANCHI - 834102 (FAX NO. 06544-225414)
5. CHIEF LOAD DISPATCHER, SLDC, OPTCL, BHUBANESWAR (FAX NO.0674-2748509)
6. CHIEF GENERAL MANAGER (O&M), OPTCL, BHUBANESWAR
7. SR. GENERAL MANAGER (PP), GRIDCO, JANPATH, BHUBANESWAR (0674-2547180)
8. DIRECTOR (OPERATION), IB TPS, AT/PO BANHARPALI, JHARSUGUDA, (FAX NO. 06645-222225/222230)
9. GENERAL MANAGER, TTPS, TALCHER, (FAX NO. 06760-243212)
10. SR. GENERAL MANAGER (ELECTRICAL), OHPC LTD., BHUBANESWAR, (FAX NO.0674-2542102)
11. CHIEF ENGINEER, CLD, WBSETCL, HOWRAH, (FAX NO. 033-26886232)
12. CHIEF ENGINEER, CENTRAL PLANNING WING, WBSETCL, SALT LAKE (FAX NO.: 033-23591955)
13. CHIEF ENGINEER (PTR), WBSEDCL, SALT LAKE, KOLKATA (FAX:033-23345862)
14. CHIEF GENERAL MANAGER (OS), WBPDC, KOLKATA-98 (FAX NO. 033-23393286/2335-0516)
15. GM, KOLAGHAT TPS, WBPDC, KOLAGHAT (FAX NO.03228231280)
16. DGM (OPERATION), DPL, DURGA PUR, (FAX NO. 0343-2555052)
17. GM (SYS OPERATION), CESC, CHOWRINGHEE SQUARE, KOLKATA (FAX NO.033-22253756/22129871)
18. CHIEF ENGINEER, SLDC, DVC, HOWRAH (FAX NO. 033-2688-5094)
19. ADDL.CHIEF ENGINEER, SLDC, POWER DEPT., GOVT. OF SIKKIM, GANGTOK, (FAX NO. 03592-228186/201148/202284)
20. EXECUTIVE DIRECTOR, ERLDC, POSOCO, KOLKATA, (FAX NO. 033-2423-5809)
21. GENERAL MANAGER, FSTPP, NTPC, FARAKKA, (FAX NO. 03512-224214/226085/226124)
22. GENERAL MANAGER , KhSTPP, NTPC, KAHALGAON (FAX NO.06429-226082)
23. GENERAL MANAGER, TSTPP, NTPC, TALCHER, (FAX NO. 06760-249053)
24. GENERAL MANAGER (OS), POWERGRID, ER-II, KOLKATA(Fax no: 033-23572827)
25. GENERAL MANAGER , POWERGRID, ER-I, PATNA, (FAX NO.0612-2531192)
26. GENERAL MANAGER (O&M), POWERGRID, ODISHA PROJECTS, SAHID NAGAR, BHUBANESWAR – 751 007
27. MANAGING DIRECTOR, DRUK GREEN POWER CORPORATION, P.O. BOX -1351, THIMPU, BHUTAN —(FAX NO 00975- 2336411)
28. MANAGING DIRECTOR, BHUTAN POWER CORPORATION, P.O.BOX-580, THIMPU, BHUTAN (FAX NO. 00975-2333578)
29. CHIEF ENGINEER (O&M), TALA H.E.PROJECT, BHUTAN (FAX NO. 009752/324803)
30. EXECUTIVE DIRECTOR (O&M), NHPC, FARIDABAD (FAX No.:0129-2272413)

31. GENERAL MANAGER, TEESTA –V POWER STATION, NHPC, SINGTAM, EAST SIKKIM (FAX 03592 - 247377)
32. CHIEF ENGINEER, RANGIT POWER STATION, NHPC, P.O. RANGIT NAGAR, SOUTH SIKKIM (FAX NO.03595-259268)
33. SENIOR VICE PRESIDENT, PTC LTD., NBCC TOWERS, 15-BHIKAJI KAMA PLACE, NEW DELHI- 110066 (FAX NO. 011-41659504)
34. PLANT HEAD, ADHUNIK POWER & NATUARAL RESOURCES, JHARKHAND(FAX NO.: 0657-6628440)
35. AGM (OPERATION), MAITHON POWER LTD, DHANBAD (FAX: 08860004758)
36. VICE PRESIDENT(POWER), VEDANTA LIMITED, BHUBANESWAR- 751023 (FAX NO 0674-2302920)
37. CHIEF ELECTRICAL ENGINEER, EASTERN RAILWAY, KOLKATA-700 001 (FAX NO.: 033-22300446)
38. CHIEF ELECTRICAL ENGINEER, SOUTH EASTERN RAILWAY, KOLKATA-43 (FAX: 033-24391566)
39. DEPUTY DIRECTOR, EASTERN RPSO, SALT LAKE, KOLKATA- (FAX NO:033-23217075)
40. GENERAL MANAGER (O&M), NHPC LTD, FARIDABAD, FAX: 0129-2272413
41. ASSOCIATE VICE PRESIDENT, GMR KEL, BHUBANESWAR-751007. (FAX NO: 0674-2572794)
42. GM (SO & COMML), NTPC VVNL, NEW DELHI-110033. Fax:011-24367021
43. SHRI D. P. BHAGAVA, CHIEF CONSULTANT (O&M), TEESTA URJA LIMITED, NEW DELHI-110 001 (FAX:011-46529744)
44. SHRI BRAJESH KUMAR PANDE, PLANT HEAD, JITPL. (FAX:011-26139256-65)
45. DIRECTOR (NPC), CEA, NRPC BUILDING, KATWARIA SARAI, NEW DELHI- 110016
46. DGM (OS), HALDIA ENERGY LIMITED, BARIK BHAWAN, KOKATA-700072, FAX: 033-22360955
47. GENERAL MANAGER(O&M),BRBCL,NABINAGAR,BIHAR-824003,FAX-06332-233026

CC:

Chief Engineer, OPM, CEA	Chief Engineer, NPC, CEA	ASSISTANT SECRETARY,ERPC
--------------------------	--------------------------	-----------------------------

ERPC:: Kolkata



Annexure-I

Corrigendum to the minutes of 208th OCC Meeting

1. In 208th OCC meeting was held on 17.10.2023, certain portions of **para no:4** in **Item No: B7** was agreed to be modified as detailed below:

ORIGINAL	REVISED
<i>".....OCC strongly asserted the significance of installation of 500 MVA spare ICT at Maithon(PG) at Subhasgram(PG) to ensure reliability of power supply in and around Kolkata in coming summer and thereby urged Powergrid to expedite the ICT commissioning process at Subhasgram(PG)"</i>	<i>"OCC agreed with the proposal of Powergrid as mentioned above at point no 3(a-e) and further strongly asserted the significance of installation of 500 MVA spare ICT at Maithon(PG) at Subhasgram(PG) to ensure reliability of power supply in and around Kolkata in coming summer and thereby urged Powergrid to expedite the ICT commissioning process at Subhasgram(PG)."</i>

2. In 208th OCC meeting was held on 17.10.2023, certain portions of **para no:3** in **Item No: B8** was agreed to be modified as detailed below:

ORIGINAL	REVISED
<i>".....OCC advised Powergrid to proceed with replenishment process till the spares from Jeerat S/S and Subhasgram S/S get returned to regional pool. "</i>	<i>"OCC advised Powergrid to proceed with replenishment process as per CEA spare guidelines-2020. ."</i>